

C. DUKES SCOTT
EXECUTIVE DIRECTOR

1401 Main Street, Suite 900
Columbia, SC 29201



DAN F. ARNETT
CHIEF OF STAFF

Phone: (803) 737-0800
Fax: (803) 737-0801

jnelson@regstaff.sc.gov

Jeffrey M. Nelson
Counsel for ORS

June 3, 2009

VIA ELECTRONIC FILING

Mr. Charles Terreni
Chief Clerk/Administrator
Public Service Commission of South Carolina
P.O. Drawer 11649
Columbia, SC 29211


IN RE: Application of Avondale Mills, Incorporated for Approval of a New Schedule
of Rates and Charges for Water and Sewerage Services Provided to Customers
in Aiken County, South Carolina
Docket No. 2008-460-WS

Dear Mr. Terreni:

Enclosed please find a late filed exhibit (Hearing Exhibit #2) which is being submitted to the Commission in response to the request of Commissioner Clyburn during the hearing in this matter held on Tuesday, June 2, 2009. ORS is providing a copy of this letter and its contents to counsel for the Applicant, Mr. Scott Elliott.

If you have any questions or concerns regarding the enclosed, please contact me at your convenience.

Sincerely,



Jeffrey M. Nelson

cc: Scott Elliott, Esquire

Morgan, Willie

From: Jennifer R. Hughes [hughesjr@dhec.sc.gov]
Sent: Tuesday, June 02, 2009 4:16 PM
To: Morgan, Willie
Subject: Re: Avondale Mills, Inc. Sewerage Questions

Willie,

All complaints have been investigated and at the time of the investigation there were no on-going problems. We have communicated to the operator and maintenance personnel the requirements of reporting sewer system releases.

The Operating Permit for Satellite Sewer Systems requires:
The sewer system owner to notify the Department immediately upon discovery whenever any release:
(a) reaches the surface waters of the state, or
(b) poses a threat to human health or the environment, or
(c) exceeds an estimated 500 gallons.

Please let me know if you have any additional questions or concerns.

Jennifer Hughes, Director
Region 5 Aiken EQC
SC DHEC
803-641-7670

>>> "Morgan, Willie" <wmorgan@regstaff.sc.gov> 6/2/2009 3:14 PM >>>
Jennifer,

Can you provide an overview of your evaluation of the sewer manhole at 504 Trolley Line Road in Graniteville along with the status of other sewer issues as identified at the night hearing that was held concerning Avondale Mills, Inc.? Also, can you discuss the reporting requirement for a sewer utility as it relates to the release of sewerage from manholes and other non-authorized releases?

Thanks.

Willie J. Morgan, P.E.

South Carolina Office of Regulatory Staff

1401 Main Street, Suite 900

Columbia, South Carolina 29201

Phone: 803-737-0827

Fax: 803-737-0801

wmorgan@regstaff.sc.gov